


Voltage Stability Margin Estimation Using Machine Learning Tools

Estimación del Margen de Estabilidad de Voltaje Utilizando Herramientas de Aprendizaje Automático

 G.F. Guañuna¹

 M.S. Chamba³

 N.V. Granda¹

 J.C. Cepeda¹

 D.E. Echeverría²

 W. Vargas¹

¹Escuela Politécnica Nacional, Ecuador

E-mail: gabriel.guanuna@epn.edu.ec; nelson.granda@epn.edu.ec; jaime.cepeda@epn.edu.ec;
walter.vargas@epn.edu.ec

²Operador Nacional de Electricidad, CENACE

E-mail: decheverria@cenace.gob.ec

³CELEC EP Unidad de negocio Coca Codo Sinclair

E-mail: marlon.chamba@celec.gob.ec

Abstract

Real-time voltage stability assessment, via conventional methods, is a difficult task due to the required large volume of information, high execution times and computational cost. Based on this background, this technical work proposes an alternative method for voltage stability margin estimation through the application of artificial intelligence and data mining algorithms. For this purpose, 10 000 operate scenarios were generated through Monte Carlo simulations, considering the load variability and the n-1 security criterion. Afterwards, the voltage stability margin of all scenarios were determined using power-voltage (PV) curves in order to obtain a database. This information allowed structuring a data matrix for training and evaluating an artificial neural network and a support vector machine, capable of predicting the voltage stability margin, even in real time. The performance of the prediction tools was evaluated through the mean square error and the coefficient of determination. The proposed methodology was applied to the IEEE 14 bus test system, showing so promising results for both the neural network and the vector machine, where the coefficients of determination were 0.9153 and 0.8317, respectively.

Index terms— Voltage stability assessment, Monte Carlo method, voltage stability margin estimation, artificial intelligence algorithms.

Resumen

La evaluación de la estabilidad de voltaje en tiempo real, mediante métodos convencionales, resulta en una tarea difícil debido al gran volumen de información, los elevados tiempos de ejecución y el esfuerzo computacional requerido. Con estos antecedentes, el presente trabajo técnico propone un método alternativo que permite la estimación del margen de estabilidad de voltaje a través de la aplicación de algoritmos de inteligencia artificial y minería de datos. Para ello, se generaron 10 000 escenarios operativos mediante simulaciones de Monte Carlo, considerando la variabilidad de la carga y el criterio de seguridad n-1. Posteriormente, se determinaron los márgenes de estabilidad de voltaje de todos los escenarios mediante el uso de las curvas voltaje-potencia (PV, por sus siglas en inglés), con la finalidad de obtener una base de datos. Esta información permitió estructurar una matriz de datos para entrenar y evaluar la red neuronal artificial y la máquina vectorial de soporte, capaz de predecir el margen de estabilidad de voltaje, incluso en tiempo real. El desempeño de las herramientas de predicción se evaluó a través del error cuadrático medio y del coeficiente de determinación. La metodología propuesta se aplicó al sistema de prueba IEEE 14 bus, mostrando resultados prometedores tanto para la red neuronal como para la máquina vectorial, donde los coeficientes de determinación fueron 0.9153 y 0.8317, respectivamente.

Palabras clave— Evaluación de la estabilidad de voltaje, método de Monte Carlo, estimación del margen de estabilidad de voltaje, algoritmos de inteligencia artificial.

Recibido: 27-03-2023, Aprobado tras revisión: 14-06-2023

Forma sugerida de citación: Guañuna, G.; Chamba, M.; Granda, N.; Cepeda, J.; Echeverría, D.; Vargas, W. (2023). "Voltage Stability Margin Estimation Using Machine Learning Tools". Revista Técnica "energía". No. 20, Issue I, Pp. 1-8

ISSN On-line: 2602-8492 - ISSN Impreso: 1390-5074

Doi: <https://doi.org/10.37116/revistaenergia.v20.n1.2023.570>

© 2023 Operador Nacional de Electricidad, CENACE



1. INTRODUCTION

The increase of electricity load as well as the existence of new economic and environmental constraints on generation dispatch and expansion of transmission systems have caused the Electrical Power System (EPS) to operate closer to its operating limits. In these new operating conditions, the static and dynamic security can be affected by voltage stability problems [1]. According to [2], voltage instability causes a progressive and uncontrolled decrease of bus voltages after a disturbance, a sudden increase in electrical load, a change in system operating conditions or a combination of all of them. Cepeda *et al.* established most of these events occur in stressed EPS, where generators fail to maintain normal voltage profiles at the busbars and transmission lines are congested [3].

Currently, in the technical literature, several approaches for voltage stability assessment have been proposed: active power-voltage (PV) and reactive power-voltage (Q-V) curves, modal analysis, sensitivity studies, application of voltage stability indices and continuous power flow (CPF), all of them for static analysis, as shown by Patidar and Sharma [4]. However, from a real-time perspective, such approaches require a large amount of time and computational effort for the execution of these methodologies. On the other hand, artificial intelligence-based algorithms are the most important tools to perform real-time static or dynamic security monitoring and assessment of EPS by predicting voltage, frequency and angle stability margins.

As demonstrated in [5], today, machine learning (ML) based techniques such as artificial neural networks (ANNs), decision trees (DTs), fuzzy logic (FL), adaptive neuro-fuzzy inference system (ANFIS) and support vector machines (SVMs) have become attractive tools for solving nonlinear problems with desired speed and accuracy. In particular, deep learning is used in [6], for short-term voltage stability assessment of power systems to learn the dependencies from post-disturbance system dynamic trajectories. In this connection, it is important to highlight that most of the current proposed methodologies, oriented to use artificial intelligence-based algorithms, have been applied to test power systems, but their implementation to actual power systems, together with proper contingencies consideration continues to be scarce.

Based on these facts, this paper presents a novel methodology based on artificial neural networks, specifically multi-layer perceptron (MLP), and support vector regression (SVR), to estimate the voltage stability margin (VSM) using a validated database generated by Monte Carlo simulations. The proposal is applied to the IEEE 14 bus test power system.

The rest of the paper is organized as follows. A theoretical review of voltage stability assessment methodologies is presented in Section 2. Section 3

describes the proposed methodology that considers the database generation, data processing and considerations for machine learning training and testing. Moreover, Section 4 shows the application example and obtained results. Finally, the main conclusions are stated in Section 5.

2. THEORETICAL REVIEW

2.1. Voltage Stability definition

According to IEEE (Institute of Electrical and Electronics Engineers) / CIGRE (International Council on Large Electric Systems), voltage stability refers to the ability of a power system to maintain steady voltages at all buses in the system after being subject to a disturbance [7]. The phenomenon that occurs when the electric system is unable to meet demand with steady voltages under stress conditions is known as voltage instability. According to [8], the factors contributing to voltage stability are the generators' reactive power limits, outage of any equipment (transmission lines, generators or transformers), load characteristics, characteristics of reactive compensation devices and the action of voltage control devices.

2.2. PV curves

PV curves are essential to analyze the voltage stability of an EPS. They allow finding the critical voltage instability point by increasing the power load until the power flow does not converge (stability limit), as shown by Amroune [9]. As demonstrated in [10], a methodology is proposed to determine the voltage profile power transfer limits of the monitored transmission corridors using the Thevenin Equivalent method and the determination of the PV curve in real-time. This allows voltage stability assessment in real time and constitutes an important basis for early-warning indicators. However, this methodology assumes the availability of phasor measurement units (PMU) at both sending and receiving ends of the transmission corridor, which is not always possible, Reddy *et al.* [11] and Lee and Han [12].

One of the most frequent terms related to voltage instability is the voltage stability margin (VSM), which corresponds to a measure of the distance from the initial operating point to the critical point, as illustrated in Fig.1. In the figure, voltages decay when there is an increase in the transmitted active power. The voltage stability limit is at the critical point (B), while the initial operating point (A) corresponds to a less loaded state. The curve above the critical point is known as the stable part, whereas the rest of the curve is known as the unstable part. In addition, if there is a change in the power factors of the loads, the curves also change because a new operating point of the system appears and thus a new voltage stability limit, as shown by Patiño and Limas [13].

According to Fig. 1, the VSM can be calculated using the initial operating point and critical point as:

Where:

- P_{max} : Final power of the loads in [MW].
- P_0 : Base power of loads in [MW].

$$ME = \frac{P_{max} - P_0}{P_0} \quad (1)$$

Therefore, a high VSM value denotes a more stable EPS, since it can transfer more power until the stability limit is reached. On the other hand, according to [14], a low index value indicates the power transfer is limited because the system is more stressed, and therefore, the system is more prompt to voltage instability. A secure operation region definition, through the application of PV curves, is useful to operators when taking preventive or corrective measures in real time operation. In this sense, this range of limits is subjective because it is related to operating regulations, technical reports, operating experience, among others.




Figure 1: PV curve example [13]

To give an example, the alert and alarm limits associated with voltage stability are determined by the approach adopted in [15], which shows how measurements from distributed PMUs can be combined with relevant transmission lines' parameters, and be handled to detect forthcoming voltage stability problems in power systems at early stage.

In this paper, iterative power flow computations, based on the PowerFactory PV curve analysis module, is performed to create a VSM database [16].

2.3. Monte Carlo method as scenario generation tool

The Monte Carlo method allows, through successive deterministic power flows, to solve probabilistic power flows. The application of the Monte Carlo method for the analysis of probabilistic power flows allows considering the stochasticity of the system behavior with the purpose of performing a study closer to reality, as demonstrated in [17].

In stability studies, the Monte Carlo method has allowed the generation of multiple probable scenarios to determine system security indexes. In [18], a methodology is proposed to assess the load uncertainty impact on the transient stability of EPS based on probabilistic analysis of the Critical Clearing Time. Monte Carlo method has also been used to determine different operating conditions to establish voltage stability indexes of transmission lines.

In this paper, Monte Carlo simulation is applied to perform iterative simulations oriented to determine the VSM of several operating scenarios, including the n-1 security criterion. For this aim, the scripting capability of PowerFactory is used to iteratively control the PV curve analysis tool from Python.

2.4. Voltage stability assessment using machine learning techniques

There are different approaches for voltage stability analysis such as PV and QV curves, modal analysis, voltage stability indices (VSI) and continuation power flows (CPF). However, the application of these tools in real time to large SEPs is inconvenient due to the computational effort required by the high number of iterations related to the methods. That said, alternative approaches related to machine learning models (MLM) need to be explored to overcome this computational problem by interacting with technological tools, high-level programming languages and data mining. The ML includes many techniques such as artificial neural networks (ANNs), decision trees (DTs), fuzzy logic (FL), adaptive neuro-fuzzy inference system (ANFIS), support vector machines (SVMs), among others.

Machine learning is a branch of artificial intelligence that groups a set of methods for the creation of models that learn from data with the purpose of making a prediction or inference, as shown by Flach [19]. In this regard, an approach to estimate the VSM using artificial intelligence tools is presented in [20]. This methodology applies voltage stability indexes (VSI) calculated from synchrophasor measurements.

On the other hand, a new approach to estimate the voltage stability margin through the combination between a kernel extreme learning machine (KELM) and a mean-variance mapping optimization (MVMO) algorithm is presented in [21], where the Monte Carlo method is employed to build the database for model training and validation. A comprehensive review of the application of machine learning tools such as artificial neural networks (ANN), decision tree (DT), support vector machines (SVM), for power system studies, especially in cyber-attack detection, PQ perturbation studies and dynamic security assessment studies is presented in [22].

Machine learning algorithms are mainly split into two groups:

2.4.1 Supervised algorithms

These algorithms use labeled data sets to create a model that, using a vector of input and output features, predicts the label of the feature vector. Regression and classification are the two sub-groups associated with supervised learning. In this regard, artificial neural networks and support vector machines are used in this paper in their regression versions for predicting the VSM of the power system.

2.4.2 Unsupervised algorithms

These algorithms use an unlabeled dataset to find a final structure in the data, using only one set of inputs, as shown Echeverría [23]. The main purposes of these algorithms are the data dimensionality reduction and clustering. In this connection, the principal component analysis (PCA) is used in this paper.

3. METODOLOGY

This technical work estimates the voltage stability margin of an EPS using machine learning tools and a database generated by Monte Carlo simulations. For this purpose, Python programming language and PowerFactory software are used. In the first stage, a validation of PowerFactory PV curves module using Matpower is performed. The stage two consists of database generation, data processing and machine learning algorithms application. Finally, VSM estimation and results analysis are performed in stage three. Fig. 2 schematizes the proposed methodology.




Figure 2: Methodology stages for estimating the voltage stability margin

3.1. Stage 1: Matpower and PowerFactory

The validation of PowerFactory PV curves module using Matpower allows to establish the theoretical-technical support to implement the methodology of this study. This comparison is performed to verify how close to the nose of PV curves can be reached by the algorithm implemented in PowerFactory since it does not exactly accomplish CPF formal theory, whereas Matpower does. The standard IEEE 14 bus test system is used as a case study for this purpose.

3.2. Stage 2: Software development

The technical study aims to estimate the voltage stability margin from a validated database, considering machine learning algorithms. The following sections present the general procedure developed for database

generation, data processing and considerations for the implemented algorithms.

3.2.1 Database generation

During the implementation of the simulation proposal, two processes are taken into account. The first process consists of generating the operational scenarios through communication between Python and PowerFactory. This process uses Monte Carlo method to generate multiple operating scenarios considering the variability of the load. For this purpose, optimal power flows (OPF) are first executed by PYPOWER. According to [24], PYPOWER is a power flow and OPF solver, which is a port of MATPOWER to the Python programming language.

On the one hand, the Monte Carlo method allows considering the uncertainty of the demand, while the optimal power flows are used to obtain a proper dispatch of the generation units. It should be noted that the use of OPF in the face of load variations allows solving the problem associated with congestion of transmission lines near the slack generator when only power flows are used.




Figure 3: Flowchart for the generation of operational states

Fig. 3 shows the procedure adopted for the generation of operating states, where the input data are: the operating states in DIgSILENT PowerFactory, the generating costs of each unit and the stochasticity of each system load represented by probability density functions (PDF).

On the other hand, the second process allows the calculation of the VSM from the PV curves obtained from each operating scenario, generated by Monte Carlo simulations. These stability margins are arranged in a large matrix relating the main system variables. In addition, a set of transmission lines is chosen for each system under study, and in this way, through programming, the "n-1" criterion is assessed at the time of executing a power flow or the PV curves module. In this connection, all the information, including the stability margin, is stored in pre-contingency and post-contingency data sets. The execution of this procedure developed in Python can be done directly in PowerFactory or through an external connection known as "engine mode", which allows the program to be controlled without the need for it to be open.

3.2.2 Data processing

The data processing is performed in the Python programming environment, due to its versatility when handling variables and the extensive documentation with respect to machine learning and data mining models. In this sense, the whole set of data obtained is structured and debugged to obtain the pre-contingency and post-contingency matrices, considering the individuals or samples by the number of rows, while, the features by the number of columns. The number of rows is set to 10,000 samples and the number of columns depends on the system or region of analysis (the features are the set of electrical variables that reflect the system steady-state of each operating scenario). After this, a reduction of the matrix dimensions is performed by means of PCA, considering that, in order to reduce the number of features.




Figure 4: Flow chart for the implementation of the established models

Once the files containing all the information from the base case, pre-contingency case and post-contingency case have been created, the data are processed so that they can be used by the machine learning algorithms and the models performance is evaluated, consequently. Fig. 4 shows the program flow chart for data structuring and processing.

3.2.3 Considerations

Artificial neural networks and support vector machines available in the "Scikit-learn" library (machine learning and data analysis library developed in Python programming language) are trained and implemented. The hyperparameters inside each model can be modified according to the specific documentation. It should be emphasized that, during the modeling of the regressors, the input variables are found in the pre-contingency matrix and the output variables are found in the post-contingency matrices, this approach will allow to properly perform the training and validation of the regressors. In addition, hyperparameters optimization of each model is performed using GridSearchCV, as shown Predregosa *et al.* [25].

3.3. Stage 3: Results

Finally, the obtained results are analyzed by calculating the mean square error (MSE) and the coefficient of determination (R^2) for the purpose of assessing the performance of each regressor. According to [26], MSE shows the average squared difference between the obtained and predicted values. A value close to zero of MSE indicates that the model fits the data set properly. R^2 , on the other hand, quantifies the linear relationship between the obtained value and the predicted value. A value close to "one" indicates that the model presents an appropriate fit. The entire process is performed using cross-validation.

4. RESULTS – APPLICATION TO THE IEEE 14 BUS SYSTEM

The implemented algorithms are assessed through an optimization of the hyperparameters of each model, allowing to verify how well they fit the database. In addition, eight transmission lines are selected based on contingency analysis, to assess the "n-1" criterion. In this case, eight transmission lines were considered to calculate the VSM and to obtain the information of the pre and post-contingency system variables. For this reason, eight regressors were used. However, performance index results are only presented when transmission line "6-13" is out of service.

Fig. 5 shows the reduction of the voltage stability margin of the critical bus of the system, before and after the occurrence of the contingency. This demonstrates the capability of the system to adjust to the active and reactive power requirements.




Figure 5: Example of PV curves before and after the L/T 6-13 operation exit

Table 1 shows the results for both the artificial neural network and the support vector machine. In this regard, for SVM, MSE gets worse when the optimization is applied since the error increases, while, R^2 index, also gets worse due to the fact that it moves away from one. For these reasons it can be said that SVM does not correctly fit to the data set. Whereas, for ANN, MSE improves when the optimization is applied since the error is reduced, while, R^2 index, also improves because it is closer to unity. As a conclusion, ANN approach fits better to the data set.

Table 1: Resultados de los índices de rendimiento - L/T 6-13

Models \ Indexes	MSE	R^2
ANN	0.07436	0.89741
SVM	0.07637	0.90199
ANN - GridSearchCV	0.06599	0.91531
SVM - GridSearchCV	0.13115	0.83171

The implemented models are adjusted depending on the established data set, i.e., the results obtained when the SVM is applied to the test system are not so efficient since it worsens the performance indexes. This can be justified by the outliers and the behavior of the system when calculating the stability margin by means of the PV curves. With this in mind, analyzing the case study, it is concluded that the best machine learning algorithm is the artificial neural network, since it presents a better prediction of the stability margin VSM post-contingency VSM pre-contingency before and after the optimizer. In addition, the proposed methodology was applied to the Ecuadorian National Interconnected System, demonstrating the robustness of the application and the improvement of performance indexes.

5. CONCLUSIONS

The machine learning model structuring requires to define the percentage of data to be used for training, validation and testing of the model. For the present case, 80% was for training and 20% for model evaluation. However, the use of validation data set causes a considerable loss of samples which affects machine

learning, in that sense, cross-validation method was implemented to take advantage of the largest amount of data for the final assessment of the model.

The neural network and the support vector machine present adequate performance indexes to the voltage stability margin prediction. In particular, when the optimizer was used, R^2 for ANN was 0.9153, and for SVM was 0.8317. Similar R^2 results were obtained when the optimizer was not applied. However, when the optimizer was used, MSE for ANN was 0.0659, and for SVM was 0.1311. Therefore, the artificial neural network has the best prediction and therefore it is the regressor that best fits the data set of the tackled problem.

The load variability was performed through a percentage change in the loads, however, it is recommended to use daily load curves (industrial, commercial and residential) to know the real load behavior in a 24-hour time interval.

REFERENCIAS BIBLIOGRÁFICAS

- [1] J. Rueda et al., “Dynamic Vulnerability Assessment and Intelligent Control for Sustainable Power Systems,” Wiley-IEEE Press, 2018.
- [2] C. Andersson, J. E. Solem, and B. Eliasson, “Classification of power system stability using support vector machines,” 2005 IEEE Power Eng. Soc. Gen. Meet., vol. 1, no. 2, pp. 650–655, 2005, doi: 10.1109/pes.2005.1489266.
- [3] N. P. Patidar and J. Sharma, “Loadability margin estimation of power system using model trees,” 2006 IEEE Power India Conf., pp. 338–343, 2005, doi: 10.1109/POWERI.2006.1632534.
- [4] M. Bilgen and S. Ozdemir, “Comparison of Real-Time Voltage Stability Assessment Methods,” 13th Int. Conf. Electr. Electron. Eng., pp. 73–77, 2021, doi:10.23919/ELECO5474.2021.967773 4.
- [5] A. Adhikari, S. Naetiladdanon, A. Sagswang, and S. Gurung, “Comparison of voltage stability assessment using different machine learning algorithms,” 2020 IEEE 4th Conf. Energy Internet Energy Syst. Integr. Connect. Grids Towar. a Low-Carbon High-Efficiency Energy Syst. EI2 2020, pp. 2023–2026, 2020, doi: 10.1109/EI250167.2020.9346750.
- [6] M. Zhang, J. Li, Y. Li, and R. Xu, “Deep Learning for Short-Term Voltage Stability Assessment of Power Systems,” IEEE Access, vol. 9, pp. 29711–29718, 2021.
- [7] N. Hatzigiorgiou et al., “Definition and Classification of Power System Stability - Revisited & Extended,” IEEE Trans. Power Syst., vol. 36, no. 4, pp. 3271–3281, 2021, doi: 10.1109/TPWRS.2020.3041774.



- [8] M. Amroune, "Machine Learning Techniques Applied to On-Line Voltage Stability Assessment: A Review," *Arch. Comput. Methods Eng.*, vol. 28, no. 2, pp. 273–287, 2021, doi: 10.1007/s11831-019-09368-2.
- [9] P. Kundur, *Power System Stability And Control*. New York: McGraw-Hill, 1994.
- [10] J. Cepeda, P. Verdugo, and G. Argüello, "Monitoreo de la Estabilidad de Voltaje de Corredores de Transmisión en Tiempo Real a partir de Mediciones Sincrofásicas," *Rev. EPN*, vol. 33, no. 3, 2014.
- [11] A. Reddy, K. Ekmen, V. Ajarapu, and U. Vaidya, "PMU based real-time short term voltage stability monitoring - Analysis and implementation on a real-time test bed," *North Am. Power Symp. NAPS*, 2014, doi: 10.1109/NAPS.2014.6965485.
- [12] Y. Lee and S. Han, "Real-time voltage stability assessment method for the Korean power system based on estimation of Thévenin equivalent impedance," *Appl. Sci.*, vol. 9, no. 8, 2019, doi: 10.3390/app9081671.
- [13] G. F. Patiño and G. A. Limas, "Metodologías para el análisis de estabilidad de tensión en estado estacionario," B.S. thesis, Univ. Tecnológica de Pereira, 2008.
- [14] L. Chiza and J. Cepeda, "Predicción del Margen de Estabilidad de Corredores de Transmisión Aplicando Criterios de Minería de datos y Algoritmos de Machine Learning," *Rev. Técnica "energía"*, vol. 18, no. 1, pp. 37–47, 2021, doi: 10.37116/revistaenergia.v18.n1.2021.466.
- [15] Y. Narcisse and N. Tchokonte, "Real time identification and monitoring of the voltage stability margin in electric power transmission systems using synchronized phasor measurements," Ph.D. dissertation, Univ. Kassel, Germany, 2009.
- [16] DIGSILENT GmbH. *PowerFactory 2021 - User Manual*. (2021). Accessed: Oct. 16, 2022. [Online]. Available: <https://www.digsilent.de/en/downloads.html>
- [17] B. Marah and A. O. Ekwue, "Probabilistic load flows," *Proc. Univ. Power Eng. Conf.*, vol. 2015-Novem, no. 1, 2015.
- [18] M. S. Chamba, W. A. Vargas, and J. Cristobal Cepeda, "Stochastic assessment and risk management of transient stability based on powerfactory and python interface," *IEEE PES Transm. Distrib. Conf. Exhib. - Lat. Am. T D LA*, 2020.
- [19] P. Flach, *Data, Machine Learning: The Art and Science of Algorithms that Make Sense of*. Cambridge University Press, 2012.
- [20] K. D. Dharmapala, A. Rajapakse, K. Narendra, and Y. Zhang, "Machine Learning Based Real-Time Monitoring of Long-Term Voltage Stability Using Voltage Stability Indices," *IEEE Access*, vol. 8, pp. 222544–222555, 2020.
- [21] W. M. Villa-Acevedo, J. M. López-Lezama, and D. G. Colomé, "Voltage stability margin index estimation using a hybrid kernel extreme learning machine approach," *Energies*, vol. 13, no. 4, 2020, doi: 10.3390/en13040857.
- [22] O. A. Alimi, K. Ouahada, and A. M. Abu-Mahfouz, "A Review of Machine Learning Approaches to Power System Security and Stability," *IEEE Access*, vol. 8, pp. 113512–113531, 2020, doi: 10.1109/ACCESS.2020.3003568.
- [23] D. E. Echeverría, "Evaluación y mejora de la estabilidad transitoria de sistema eléctricos en tiempo real utilizando PMUs," Ph.D. dissertation, Univ. Nacional de San Juan, 2021.
- [24] R. Lincoln, *PyPower Documentation* (2017). [Online]. Available: <https://rwl.github.io/PYPOWER/PYPOWER.pdf>
- [25] F. Predregosa et al., "Scikit-learn: Machine Learning in Python," *J. Mach. Learn. Res.*, vol. 12, pp. 2825–2830, 2011, [Online]. Available: https://scikit-learn.org/stable/modules/cross_validation.html#cross-validation.
- [26] S. Kokoska and D. Zwillinger, *Standard Probability and Statistics Tables and Formulae*. New York, 2000.



Gabriel F. Guañuna.- Nació en la ciudad de Quito - Ecuador, en 1997. Cursó sus estudios secundarios en Quito, en el Colegio Técnico Salesiano Don Bosco Kennedy, donde obtuvo el título de bachiller técnico en Instalaciones, Equipos y Máquinas Eléctricas. Obtuvo su título de Ingeniero Eléctrico en 2022 en la Escuela Politécnica Nacional. Es miembro voluntario en, IEEE Student Branch Escuela Politécnica Nacional en el capítulo Power & Energy Society. Áreas de Interés: Estabilidad de voltaje, redes inteligentes y operación de sistema eléctricos de potencia, machine learning.



Marlon S. Chamba.- Nació en Loja, Ecuador, en 1982. Obtuvo su título de Ingeniero Eléctrico en 2007 en la Escuela Politécnica Nacional, Quito-Ecuador. Realizó su doctorado en el Instituto de Energía Eléctrica, Universidad

Nacional de San Juan, San Juan, Argentina, favorecido con una beca del Servicio Alemán de Intercambio Académico (DAAD). Finalmente obtuvo el título de Doctor en Ingeniería Eléctrica en 2016. Sus campos de interés especiales comprenden el control y la estabilidad de los sistemas de energía en tiempo real, tecnología de medición sincrofasorial, los sistemas de monitoreo de área amplia, el desarrollo de redes inteligentes, la confiabilidad de los sistemas de energía y el despacho económico de energía.



Nelson V. Granda.- Obtuvo el título de Ingeniero Eléctrico en la Escuela Politécnica Nacional en el año 2006 y de Doctor en Ciencias de la Ingeniería Eléctrica en la Universidad Nacional de San Juan (Argentina), en el año 2015. Se ha desempeñado como Ingeniero

Eléctrico en varias instituciones del sector eléctrico y petrolero como son el Operador Nacional de Electricidad (CENACE), Petroamazonas EP y CELEC-EP TRANSELECTRIC. Actualmente, se desempeña como parte del staff docente del Departamento de Energía Eléctrica de la Escuela Politécnica Nacional. Sus áreas de interés son análisis y control de sistemas eléctricos de potencia en tiempo real y aplicaciones de Sistemas de Medición de Área extendida (WAMS) basados en unidades de medición sincrofasorial (PMU).



Jaime C. Cepeda.- Nació en Latacunga, Ecuador en 1981. Obtuvo el título de Ingeniero Eléctrico en la Escuela Politécnica Nacional EPN en 2005, y obtuvo su doctorado en Ingeniería Eléctrica en el Instituto de Energía Eléctrica de la Universidad Nacional de San

Juan, San Juan, Argentina. Además, obtuvo el título de Máster en Big Data por la Universidad Europea Miguel de Cervantes, Valladolid, España en 2021. Actualmente se desempeña como profesor universitario a tiempo completo en programas de Maestrías y Doctorado en la EPN. Sus campos de interés especial comprenden el modelado de sistemas de potencia, la evaluación de la seguridad, la tecnología de medición sincrofasorial, el monitoreo de área amplia, los sistemas de protección y control, y la aplicación de técnicas de inteligencia computacional en el análisis de los sistemas de potencia.



Diego E. Echeverría.- Obtuvo su título de Ingeniero Eléctrico en 2006 en la Escuela Politécnica Nacional, Quito-Ecuador. Realizó su doctorado en el Instituto de Energía Eléctrica, Universidad Nacional de San Juan, San Juan, Argentina, favorecido con una beca

del Servicio Alemán de Intercambio Académico (DAAD). Obtuvo el título de Doctor en Ingeniería Eléctrica en diciembre de 2021. Actualmente trabaja en Ecuador en el Operador Nacional de Electricidad CENACE como Subgerente Nacional de Investigación y Desarrollo. Sus campos de interés especiales comprenden el control y la estabilidad de los sistemas de energía en tiempo real, la tecnología de medición sincrofasorial, los sistemas de monitoreo de área amplia y el desarrollo de redes inteligentes.



Walter Vargas.- Nació en Guayaquil, Ecuador en 1984- Recibió sus títulos de Ingeniero en Electricidad, especialización Potencia (2007) en la Escuela Superior Politécnica del Litoral y el de Máster en Sistemas de Energía Eléctrica (2013) en la Universidad

de Sevilla. Entre 2013 y el 2017 trabajó en la sección de Estudios Eléctricos del Departamento de Centro de Operaciones de CELEC EP – Transelectric. Actualmente se desempeña como profesor universitario a tiempo completo en la EPN. Sus áreas de interés incluyen la optimización, confiabilidad, evaluación de vulnerabilidad en tiempo real y el desarrollo de Smart Grids.